

Add Gas Heat Pumps to C403 (2261)

IECC: C403.3.2.3 (New)

Proponents: Gary Heikkinen, Gary W Heikkinen Energy Consulting, American Gas Association (gary.heikkinen@nwnatural.com)

2024 International Energy Conservation Code [CE Project]

Add new text as follows:

C403.3.2.3 Gas-Fired Heat Pumps. Allowed equipment shall be tested and rated in accordance with CSA/ANSI Z21.40.4 - CSA 2.94.

Reason: This proposal adds gas heat pumps as approved equipment and provides language regarding testing and rating procedures.

Cost Impact (Detailed): The change proposal is editorial in nature or a clarification and has no cost impact on the cost of construction

Justification:

This proposal simply adds gas heat pumps to the list of approved equipment and provides language on rating and testing procedures.